

MyStationPerformance.Com

O. Brogdon, V. Husson, P. Stevens, H. Vo

NASA SLR/VLBI Program
Honeywell Technology Solutions Inc.
7515 Mission Drive
Lanham, MD 20706 USA

E-mail(s): van.husson@honeywell-tsi.com, oscar.brogdon@honeywell-tsi.com, paul.stevens@honeywell-tsi.com, hoai.vo@honeywell-tsi.com




Why?

- Performance problems sometimes persist for extended periods
- Some sites have limited on-site analysis capability
 - Lack automatic warning system
 - Lack long term trend analysis capability

Key Design Features

Benefit


- Web-based
- Aggregate analysis
- Dynamic
- Comprehensive
- Graphical
- User-Friendly
- Interactive
- Artificial Intelligence



Quickly Identify Performance Problems

<u>Honeywell</u>

Computer System Architecture Front End





Types of Data Bases

- Normal point data base (1995 to the present)
 - On-site processing statistics (RMSs, system delay, fullrate observation, etc.)
 - Met. Data
 - Data Latency
- Bias reports (LAGEOS, GPS, LEOs)
- BEST Calibration Practices
- Symptoms/causes of performance problems
- Site Logs



Site Performance Main Page

- Choices via pull down menus
 - My Metrics
 - My Symptoms/Causes
 - Best Practices
 - -My Site Log




My Metrics

- Choices via pull down menus
 - Site
 - Satellite(s)
 - Performance Categories
 - -Data Quantity
 - -Data Quality
 - Operational Compliance



My Metrics Example

- Site: Maidanak (1864)
 - Satellite(s): all
 - Category: Met. Data
 - Sub-Category: Pressure
 - » Chart: Monthly Time Series





My Symptom/Causes Example

- Symptom excessive range bias (i.e. >5 meters)
 - 1. Was calibration nominal (YES/NO)?
 - 2. Was subsequent data OK (YES/NO)?
 - 3. Was this a daylight pass (YES/NO)?

Answers 1. YES, 2. YES, 3. NO

Potential Causes

- Midnight Crossing Bug in software/procedures or
- Operator Error



BEST Practices

- Choices via pull down menus
 - Laser
 - Counter
 - Detector
 - Telescope/Mount
 - Total System Calibration



BEST Practices Example

• Category: Counter

Type: Time Interval

Manufacturer & Model: SR620

BEST Practices

- Maintain strict environmental temperature control
- Minimize noise on the incoming timing signal with good grounding and shielding
- Allow for adequate warm-up time
- Use an external oscillator
- Calibrate or Cluster



Conclusions

- Very ambitious project
- Will need to conduct this in phases
- Will require support and feedback from the community, especially the Networks and **Engineering WG**
- We will provide periodic updates
- Sites should continue doing their own diagnostics and system characterization tests